



**BUREAU
VERITAS**

Certificate of compliance

Applicant: **ALTENERGY POWER SYSTEM INC.**
No.1 Yatai Road,
Jiaxing 314050 Zhejiang Province
P.R. China

Product: **Grid-tied Microinverter**

Model: **DS3D-EU
DS3D-H-EU
DS3D-L-EU
DS3D-SH-EU
DS3D, DS3D-H
DS3D-L
DS3D-SH**

Inverter for single-phase parallel connection to the public grid. The network monitoring and disconnection device is an integral part of the above-mentioned model.

Applied rules and standards:

EN 50549-1:2019

Requirements for parallel connection of installations with distribution networks - Part 1: Connection to an LV distribution network - Production of installations up to and including Type B

- 4.4 Normal operating range
- 4.5 Immunity to disturbances
- 4.6 Active response to frequency deviation
- 4.7 Power response to voltage variations and voltage changes
- 4.8 EMC and power quality
- 4.9 Interface protection
- 4.10 Connection and starting to generate electrical power
- 4.11 Ceasing and reduction of active power on set point
- 4.13 Requirements regarding single fault tolerance of interface protection system and interface switch

DIN V VDE V 0126-1-1:2006 (4.1 Functional safety)

Automatic disconnection device between a generator and the public low-voltage grid

Commission Regulation (EU) 2016/631 of 14 April 2016

Establishing a network code on requirements for grid connection of generators (NC RFG).
Type approval for generation units to use in Type A and Type B plants.

At the time of issue of this certificate, the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number: **ZEK-ESH-P21123518**

Certification Program: **NSOP-0032-DEU-ZE-V01**

Certificate number: **U22-0323**

Date of issue: **2022-06-03**

Certification body



Thomas Lammel



Certification body Bureau Veritas Consumer Products Services Germany GmbH accreditation to DIN EN ISO/IEC 17065

Testing laboratory accredited according to DIN EN ISO/IEC 17025

A partial representation of the certificate requires the written approval of Bureau Veritas Consumer Products Services Germany GmbH